



2021/22 REPORT FOR TESTING LEAD CONTENT IN DRINKING WATER OF SCHOOL FACILITIES

School District Information		Health Authority (HA) Information	
SD No.	45	Region	Vancouver Coastal Health
SD Name	West Vancouver	Contact Name	John Pickles
SD Contact Name:	Florencio de Dios	Contact Phone	604-983-6879
SD Contact Phone:	604-981-1079	Report Submitted to HA	Yes
Report Date	4/6/2022	Report Submission Date	4/6/2022

[Click here to access the School Master List for Facility Names and Facility Codes](#)

SCHOOL FACILITY INFORMATION				TEST INFORMATION						MITIGATION STRATEGY & PUBLIC COMMUNICATION PLAN		ADDITIONAL INFORMATION		
School District Number	Ministry Facility Code	School Facility Name	Year Built	Date of Test (mm/yyyy)	Total Samples	Water Fixture Type	Room Location	Lead Level Result (mg/L)	Exceed Maximum Acceptable Concentrations	Mitigation Strategy Description	Describe Public Communication Plan	Comments	Next Scheduled Date of Testing (mm/yyyy)	Ministry Submission Period
45	04545019	Bowen Island Community School	1979	Mar-22	2	Sink	Kitchen	0.001	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-22	30-Mar-22
45		Bowen Island Community School	1979	Mar-22	2	Water Filling Station	Corridor	0.002	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-22	30-Mar-22
45	04545020	Caulfeild Elementary	1957	Mar-22	2	Sink	Kitchen	0.001	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-22	30-Mar-22
45	04545020	Caulfeild Elementary	1957	Mar-22	2	Water Fountain	Upper corridor	0.002	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-22	30-Mar-22
45	04545020	Caulfeild Elementary	1957	Mar-22	2	Water Fountain	Upper corridor	0.000	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-22	30-Mar-22
45	04545030	Chartwell Elementary	1966	Mar-22	2	Sink	Kitchen	0.002	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-23	30-Mar-22
45	04545030	Chartwell Elementary	1966	Mar-22	2	Water Fountain	Upper corridor	0.000	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-23	30-Mar-22
45	04545030	Chartwell Elementary	1966	Mar-22	2	Water Fountain	Lower corridor	0.003	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-23	30-Mar-22
45	04545035	Cypress Park Primary	1966	Mar-22	2	Sink	Kitchen	0.000	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-22	30-Mar-22
45	04545035	Cypress Park Primary	1966	Mar-22	2	Water Fountain	Corridor	0.000	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-22	30-Mar-22
45	04545040	Eagle Harbour Montessori	1967	Mar-22	2	Sink	Kitchen	0.001	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-22	30-Mar-22
45	04545040	Eagle Harbour Montessori	1967	Mar-22	2	Water Fountain	Corridor	0.002	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-22	30-Mar-22
45	04545025	Ecole Cedardale Elementary	1954	Mar-22	2	Water Fountain	Corridor	0.002	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-23	30-Mar-22
45	04545025	Ecole Cedardale Elementary	1954	Mar-22	2	Water Fountain	Corridor	0.000	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-23	30-Mar-22
45	04545025	Ecole Cedardale Elementary	1954	Mar-22	2	Water Fountain	Corridor	0.000	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-23	30-Mar-22
45	04545025	Ecole Cedardale Elementary	1954	Mar-22	2	Sink	Kitchen	0.000	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-23	30-Mar-22
45	04545065	Ecole Pauline Johnson Elementary	1922	Mar-22	2	Water Fountain	Corridor	0.000	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-23	30-Mar-22
45	04545065	Ecole Pauline Johnson Elementary	1922	Mar-22	2	Water Fountain	Corridor	0.000	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-23	30-Mar-22
45	04545065	Ecole Pauline Johnson Elementary	1922	Mar-22	2	Sink	Kitchen	0.001	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-23	30-Mar-22

SCHOOL FACILITY INFORMATION				TEST INFORMATION						MITIGATION STRATEGY & PUBLIC COMMUNICATION PLAN			ADDITIONAL INFORMATION	
School District Number	Ministry Facility Code	School Facility Name	Year Built	Date of Test (mm/yyyy)	Total Samples	Water Fixture Type	Room Location	Lead Level Result (mg/L)	Exceed Maximum Acceptable Concentrations	Mitigation Strategy Description	Describe Public Communication Plan	Comments	Next Scheduled Date of Testing (mm/yyyy)	Ministry Submission Period
45	04545045	Gleneagles Elementary	1950	Mar-22	2	Water Fountain	Corridor	0.000	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-22	30-Mar-22
45	04545045	Gleneagles Elementary	1950	Mar-22	2	Water Fountain	Corridor	0.000	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-22	30-Mar-22
45	04545045	Gleneagles Elementary	1950	Mar-22	2	Water Fountain	Corridor	0.000	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-22	30-Mar-22
45	04545045	Gleneagles Elementary	1950	Mar-22	2	Sink	Kitchen	0.001	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-22	30-Mar-22
45	04545055	Hollyburn Elementary	1912	Mar-22	2	Water Fountain	Corridor	0.000	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-24	30-Mar-22
45	04545055	Hollyburn Elementary	1912	Mar-22	2	Sink	Kitchen	0.000	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-24	30-Mar-22
45	04545060	Irwin Park Elementary	1955	Mar-22	2	Sink	Kitchen	0.000	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-24	30-Mar-22
45	04545060	Irwin Park Elementary	1955	Mar-22	2	Water Fountain	Corridor	0.000	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-24	30-Mar-22
45	04545060	Irwin Park Elementary	1955	Mar-22	2	Water Fountain	Corridor	0.000	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-24	30-Mar-22
45	04545060	Irwin Park Elementary	1955	Mar-22	2	Water Fountain	Corridor	0.000	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-24	30-Mar-22
45	04545062	Lions Bay Community School	1977	Mar-22	2	Sink	Kitchen	0.000	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-22	30-Mar-22
45	04545062	Lions Bay Community School	1977	Mar-22	2	Water Fountain	Corridor	0.000	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-22	30-Mar-22
45	04545070	Ridgeview Elementary	1948	Mar-22	2	Sink	Kitchen	0.001	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-24	30-Mar-22
45	04545070	Ridgeview Elementary	1948	Mar-22	2	Water Fountain	Upper corridor	0.000	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-24	30-Mar-22
45	04545070	Ridgeview Elementary	1948	Mar-22	2	Water Fountain	Lower corridor	0.000	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-24	30-Mar-22
45	04545081	Rockridge Secondary	1996	Mar-22	2	Water Fountain	Corridor	0.000	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-22	30-Mar-22
45	04545081	Rockridge Secondary	1996	Mar-22	2	Water Fountain	Corridor	0.000	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-22	30-Mar-22
45	04545081	Rockridge Secondary	1996	Mar-22	2	Water Fountain	Corridor	0.000	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-22	30-Mar-22
45	04545081	Rockridge Secondary	1996	Mar-22	2	Sink	Kitchen	0.001	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-22	30-Mar-22
45	04545081	Rockridge Secondary	1996	Mar-22	2	Sink	Kitchen	0.000	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-22	30-Mar-22
45	04545010	Sentinel Secondary	1961	Mar-22	2	Water Fountain	Upper corridor	0.000	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-23	30-Mar-22
45	04545010	Sentinel Secondary	1961	Mar-22	2	Water Fountain	Foyer	0.000	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-23	30-Mar-22
45	04545010	Sentinel Secondary	1961	Mar-22	2	Sink	Kitchen	0.001	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-23	30-Mar-22
45	04545010	Sentinel Secondary	1961	Mar-22	2	Sink	Cafeteria	0.001	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-23	30-Mar-22

SCHOOL FACILITY INFORMATION				TEST INFORMATION						MITIGATION STRATEGY & PUBLIC COMMUNICATION PLAN			ADDITIONAL INFORMATION	
School District Number	Ministry Facility Code	School Facility Name	Year Built	Date of Test (mm/yyyy)	Total Samples	Water Fixture Type	Room Location	Lead Level Result (mg/L)	Exceed Maximum Acceptable Concentrations	Mitigation Strategy Description	Describe Public Communication Plan	Comments	Next Scheduled Date of Testing (mm/yyyy)	Ministry Submission Period
45	04545010	Sentinel Secondary	1961	Mar-22	2	Water Fountain	Upper corridor	0.000	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-23	30-Mar-22
45	04545075	West Bay Elementary	1952	Mar-22	2	Sink	Kitchen	0.005	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-22	30-Mar-22
45	04545075	West Bay Elementary	1952	Mar-22	2	Water Fountain	Corridor	0.000	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-22	30-Mar-22
45	04545075	West Bay Elementary	1952	Mar-22	2	Water Fountain	Corridor	0.001	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-22	30-Mar-22
45	04545075	West Bay Elementary	1952	Mar-22	2	Water Fountain	Corridor	0.000	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-22	30-Mar-22
45	04599309	West Vancouver Inglewood Secondary	1927	Mar-22	2	Water Fountain	Kitchen	0.000	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-24	30-Mar-22
45	04599309	West Vancouver Inglewood Secondary	1927	Mar-22	2	Water Fountain	Kitchen	0.000	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-24	30-Mar-22
45	04545015	West Vancouver Secondary	1950	Mar-22	2	Water Fountain	Corridor	0.000	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-24	30-Mar-22
45	04545015	West Vancouver Secondary	1950	Mar-22	2	Water Fountain	Corridor	0.000	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-24	30-Mar-22
45	04545015	West Vancouver Secondary	1950	Mar-22	2	Water Fountain	Corridor	0.000	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-24	30-Mar-22
45	04545015	West Vancouver Secondary	1950	Mar-22	2	Water Fountain	Corridor	0.000	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-24	30-Mar-22
45	04545015	West Vancouver Secondary	1950	Mar-22	2	Water Fountain	Corridor	0.001	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-24	30-Mar-22
45	04545015	West Vancouver Secondary	1950	Mar-22	2	Water Fountain	Corridor	0.000	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-24	30-Mar-22
45	04545015	West Vancouver Secondary	1950	Mar-22	2	Sink	Kitchen	0.000	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-24	30-Mar-22
45	04545015	West Vancouver Secondary	1950	Mar-22	2	Sink	Kitchen	0.000	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-24	30-Mar-22
45	04545080	Westcot Elementary	1956	Mar-22	2	Sink	Kitchen	0.001	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-23	30-Mar-22
45	04545080	Westcot Elementary	1956	Mar-22	2	Water Fountain	Corridor	0.000	No	Daily flushing in place	Although no elevated levels of lead, will post report on SD45 website		Oct-23	30-Mar-22
45									-					30-Mar-22
45									-					30-Mar-22
45									-					30-Mar-22
45									-					30-Mar-22
45									-					30-Mar-22