

School District Information

Health Authority (HA) Information

SD No	45	Region	Vancouver Coastal Health
SD Name	West Vancouver Schools	Contact Name	John Pickles
SD Contact Name	Florencio de Dios	Contact Phone	604-983-6879
SD Contact Phone	604-981-1079	Report Submitted to HA	Yes
Report Date	2/22/2023	Report Submission Date	2/23/2023

School Identifier	Testing information						Result	
Ministry Asset Number	Test Date (dd-mm-yyy)	Time of test (24hr clock)	Outlet ID (optional)	Sample Type	Fixture Type	Fixture Location Description	Lead Result (mg/L)	Exceeds Maximum Acceptable Concentration
CEDARDALE PRIMARY	10/02/2023	06:00:00	0252	First Draw	DW	Drinking water fountain (DW), East	0.00029	No
CEDARDALE PRIMARY	10/02/2023	06:05:00	0252	Flushed	DW	Drinking water fountain (DW), East	0.00088	No
CEDARDALE PRIMARY	10/02/2023	06:05:00	0251	First Draw	DW	Drinking water fountain (DW), West	0	No
CEDARDALE PRIMARY	10/02/2023	06:10:00	0251	Flushed	DW	Drinking water fountain (DW), West	0	No
CEDARDALE PRIMARY	10/02/2023	05:45:00		First Draw	KC	Kitchen (KC)	0.0014	No
CEDARDALE PRIMARY	10/02/2023	05:50:00		Flushed	KC	Kitchen (KC)	0.00033	No
CEDARDALE PRIMARY	10/02/2023	06:10:00		First Draw	DW	Drinking water fountain (DW), Southeast, Lower Level	0	No
CEDARDALE PRIMARY	10/02/2023	06:15:00		Flushed	DW	Drinking water fountain (DW), Southeast, Lower Level	0	No
CHARTWELL ELEMENTARY	10/02/2023	06:00:00	0253	First Draw	KC	Kitchen (KC), staff room	0.001	No
CHARTWELL ELEMENTARY	10/02/2023	06:05:00	0253	Flushed	KC	Kitchen (KC), staff room	0.0031	No
CHARTWELL ELEMENTARY	10/02/2023	06:00:00	0249	First Draw	DW	Drinking water fountain (DW), upper hallway	0	No
CHARTWELL ELEMENTARY	10/02/2023	06:05:00	0249	Flushed	DW	Drinking water fountain (DW), upper hallway	0	No
CHARTWELL ELEMENTARY	10/02/2023	06:00:00	0248	First Draw	DW	Drinking water fountain (DW), lower hallway	0	No
CHARTWELL ELEMENTARY	10/02/2023	06:05:00	0248	Flushed	DW	Drinking water fountain (DW), lower hallway	0	No
HOLLYBURN ELEMENTARY	13/02/2023	05:35:00	0242	First Draw	DW	Drinking water fountain (DW), hallway	0	No
HOLLYBURN ELEMENTARY	13/02/2023	05:41:00	0242	Flushed	DW	Drinking water fountain (DW), hallway	0	No
HOLLYBURN ELEMENTARY	13/02/2023	05:45:00	0241	First Draw	KC	Kitchen faucet (KC)	0.00042	No
HOLLYBURN ELEMENTARY	13/02/2023	05:53:00	0241	Flushed	KC	Kitchen faucet (KC)	0	No

Ministry Asset Number	Test Date (dd-mm-yyy)	Time of test (24hr clock)	Outlet ID (optional)	Sample Type	Fixture Type	Fixture Location Description	Lead Result (mg/L)	Exceeds Maximum Acceptable Concentration
PAULINE JOHNSON ELEMENTARY	13/02/2023	06:00:00	0259	First Draw	DW	Drinking water fountain (DW), lower hallway	0	No
PAULINE JOHNSON ELEMENTARY	13/02/2023	06:05:00	0259	Flushed	DW	Drinking water fountain (DW), lower hallway	0	No
PAULINE JOHNSON ELEMENTARY	13/02/2023	06:00:00	0260	First Draw	DW	Drinking water fountain (DW), upper hallway	0	No
PAULINE JOHNSON ELEMENTARY	13/02/2023	06:05:00	0260	Flushed	DW	Drinking water fountain (DW), upper hallway	0	No
PAULINE JOHNSON ELEMENTARY	13/02/2023	06:10:00		First Draw	KC	Kitchen (KC), staff room	0	No
PAULINE JOHNSON ELEMENTARY	13/02/2023	06:15:00		Flushed	KC	Kitchen (KC), staff room	0	No
SENTINEL SECONDARY	09/02/2023	06:38:00	D5	First Draw	DW	Drinking water fountain (DW), mid level, South	0	No
SENTINEL SECONDARY	09/02/2023	06:43:00	D5	Flushed	DW	Drinking water fountain (DW), mid level, South	0.00067	No
SENTINEL SECONDARY	09/02/2023	06:45:00	D6	First Draw	DW	Drinking water fountain (DW), lower level, West	0	No
SENTINEL SECONDARY	09/02/2023	06:50:00	D6	Flushed	DW	Drinking water fountain (DW), lower level, West	0	No
SENTINEL SECONDARY	09/02/2023	06:51:00	D7	First Draw	DW	Drinking water fountain (DW), Field House	0.0013	No
SENTINEL SECONDARY	09/02/2023	06:56:00	D7	Flushed	DW	Drinking water fountain (DW), Field House	0.0011	No
SENTINEL SECONDARY	10/02/2023	06:14:00	D1	First Draw	DW	Drinking water fountain (DW), upper level, North	0	No
SENTINEL SECONDARY	10/02/2023	06:19:00	D1	Flushed	DW	Drinking water fountain (DW), upper level, North	0	No
SENTINEL SECONDARY	09/02/2023	06:20:00		First Draw	KC	Kitchen faucet (KC), staff room	0.00094	No
SENTINEL SECONDARY	09/02/2023	06:23:00		Flushed	KC	Kitchen faucet (KC), staff room	0.00022	No
SENTINEL SECONDARY	09/02/2023	06:27:00	D4	First Draw	DW	Drinking water fountain (DW), mid level, North	0	No

Ministry Asset Number	Test Date (dd-mm-yyy)	Time of test (24hr clock)	Outlet ID (optional)	Sample Type	Fixture Type	Fixture Location Description	Lead Result (mg/L)	Exceeds Maximum Acceptable Concentration
SENTINEL SECONDARY	09/02/2023	06:32:00	D4	Flushed	DW	Drinking water fountain (DW), mid level, North	0	No
SENTINEL SECONDARY	09/02/2023	06:02:00	D2	First Draw	KC	Kitchen faucet (KC), Cafeteria	0	No
SENTINEL SECONDARY	09/02/2023	06:07:00	D2	Flushed	KC	Kitchen faucet (KC), Cafeteria	0	No
SENTINEL SECONDARY	09/02/2023	06:32:00	D3	First Draw	DW	Drinking water fountain (DW), upper level, South	0	No
SENTINEL SECONDARY	09/02/2023	06:37:00	D3	Flushed	DW	Drinking water fountain (DW), upper level, South	0.00028	No
WESTCOT ELEMENTARY	13/02/2023	06:05:00	WCD1	First Draw	DW	Drinking water fountain (DW)	0	No
WESTCOT ELEMENTARY	13/02/2023	06:10:00	WCD1	Flushed	DW	Drinking water fountain (DW)	0	No
WESTCOT ELEMENTARY	13/02/2023	06:12:00	WCK1	First Draw	KC	Kitchen faucet (KC)	0	No
WESTCOT ELEMENTARY	13/02/2023	06:17:00	WCK1	Flushed	KC	Kitchen faucet (KC)	0	No